

Report of Analysis

Submission: 2009-002361-NYHB
Customer: Sprague
Terminal: SPRAGUE RENSSELEAR, NY
Vessel: SHORE TANK # 5 SAMPLE
Reference:
Purchase Order:
Date Received: 4-May-09
Date Analyzed: 4-May-09
Date Reported: 4-May-09

Lab Reference : 2009-002361-NYHB-004			
Sample Designated As : Shore Tank 5 Equal UML Composite NO. 6 FUEL OIL			
Method	Test	Results	Units
D4052	API Gravity @ 60 Deg F	14.4	deg API
D4294	Sulfur	0.469	Wt %

SPRAGUE PROVIDES THE ATTACHED INSPECTION REPORT/ANALYSIS REPRESENTING THE SPECIFICATIONS OF THE PRODUCT AT THE SPRAGUE TERMINAL IN TANK ON THE DATE OF INSPECTION NOTED ON THE CERTIFICATE. THIS ANALYSIS IS PROVIDED TO THE CUSTOMER FOR THE PURPOSE OF ESTABLISHING THE INDEPENDENTLY VERIFIED PRODUCT SPECIFICATION ON A COMPOSITE BASIS IN SPRAGUE'S TERMINAL SHORE TANK AS NOTED ON THE CERTIFICATE. THE INSPECTION REPORT IS NOT TO BE USED FOR ANY OTHER PURPOSE. SPRAGUE DISCLAIMS ANY LIABILITY FOR THE PRODUCT AFTER DELIVERY BY SPRAGUE TO CUSTOMER. SPRAGUE DISCLAIMS ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR AN INTENDED USE EXCEPT AS MAY BE SPECIFICALLY SET FORTH IN WRITING IN ANY CONTRACT OR TERMS OF SALE BETWEEN SPRAGUE AND A BUYER OF PRODUCT. SPRAGUE ASSUMES NO LIABILITY FOR CLAIMS OR LOSSES THAT MAY ARISE FROM CUSTOMER'S USE OF THIS INSPECTION REPORT/ANALYSIS.

Intertek Caleb Brett
Tim Zablocki, Lab Supervisor